FocalPoint[™] Optimization System Successfully Controls Emissions While Improving Heat Rate and Efficiency

PROJECT CASE HISTORY

Plant Name

Longview Power

Plant Location

Maidsville, West Virginia

Situation

After initial commissioning in 2011, this 700 MW advanced supercritical boiler, originally supplied by Foster Wheeler, was later modified to improve operation of its distributed control system (DCS), air quality control system to accommodate high-sulfur coal, and turbine.



To address issues the unit was

experiencing with slag control, Longview turned to Babcock & Wilcox (B&W) in 2016 for its Titanium® intelligent sootblowing (ISB) system. The Titanium ISB system uses a detailed boiler performance model to intelligently operate sootblowers based on actual heat transfer in each of the heat traps. The ISB allowed the plant to better control slag buildup and eliminate the large slag falls that would occur, as well as control other variables affecting heat rate such as reheat spray flow.

After the successful implementation of the Titanium ISB system, B&W presented Longview with a proposal to optimize combustion to further reduce emissions and improve heat rate. B&W installed the FocalPoint[™] optimization system on the same computer as the Titanium ISB system.

Project Description

B&W's FocalPoint system provides a wide array of performance models, general calculational functions, logic functions, knowledge-based decision algorithms, and optimization algorithms which can be combined as needed to create a customized optimization solution. The combustion optimization project had the following primary goals:

- Reduce the frequency, severity, and duration of CO spikes
- Keep CO below permit limits and reduce if possible
- Reduce the NO_x level entering the selective catalytic reduction (SCR) system to reduce ammonia usage
- Balance the O₂ across the unit
- Reduce the overall O₂ set point

To achieve these goals, the FocalPoint optimizer was given access to the biases on the following DCS control loops:

- Burner secondary air flow dampers
- Burner windbox flow dampers
- OFA flow dampers
- OFA windbox flow dampers
- O₂ set point

continued \blacktriangleright



Results

Plant operators and engineers have observed several improvements since the FocalPoint system has been in service. The system primarily runs in automatic mode, allowing operators time to focus on other operational matters. Results show the combustion optimizer's ability to deliver consistent performance improvements over a range of operating conditions.

CO emissions

- 46% reduction
- Reduced frequency of CO spikes

NO_x emissions

• 5.3% reduction in amount entering SCR, reducing the required ammonia injection rate

Furnace exit gas temperature

- Reduced variation between right and left temperature probes
- Overall average reduction of more than 200F

(Note: only includes data for loads above 700 MW)

Operating O₂

• Decrease of more than 0.5%


(Note: only includes data for loads above 700 MW)

Heat rate and efficiency

- Calculated heat rate improved by 2.6%
- Efficiency improvement of 0.58%

Summary

Heat rate and efficiency are two important metrics in which to evaluate thermal performance and cost efficiency for a plant. These results at Longview indicate that the FocalPoint system has met the combustion optimization and emissions reduction goals of the project. The heat rate and efficiency improvements are expected to result in fuel savings and reduced maintenance costs while the unit continues to meet all emissions requirements.



FocalPoint performance overview screen.

T 18	-			- 19	-												-		-		-	B 2
-		() have b																				
Louise	All I	Line .	New	Menulana																		
CD (n 10)	2	110					Fre										Re					
Ch IM			40	24	14	18	18	1.87	16	1.9	25		. 44	18	1.8	10	14	- 18	181	18	18	
0401 0432	-	815 817		8	8	8	8	10	8	10	8		÷	-		10	-	8	-	1	8	
Turing Parameters					1887	-	8	-	20	100					-	dir.	128	1	-	A		
Neg Tang SK. 17 Tan Tang SK. 17 Tan Tang SK. 16 Selonder 16 Selonder 16 Selonder 16 Selonder 16 Selonder 16 Selonder 16 Selonder 18 Selond		2862	Left		1000	URDET 10	1.00	19857	18847	-		Right	Left			10400	-	10,01	-	-		Right
		24	8	8					a				-	-			8					
				-	-	-	-	-					- 1	-	-	-	-	-	-			
to the Lord	-	20000) 3/12/00	10		1000	17	con.		đền	ano.			019		-11	our		- A		+		
tin in ing i tin in ing i	-	NON D		Ť	14.18				_		-			Ť	-						1	
inter Alter Rischaften F	eriene .	38.1 39		1	_		_			-				1						_		
-	-										1			-								
	Targe 7			10000		-	-	-	1	1 1	inar.			No. of Concession, Name				anti-re-				

FocalPoint damper overview screen.

The Babcock & Wilcox Company

1200 E Market Street, Suite 650 Akron, Ohio, U.S.A. 44305 Phone: +1 330.753.4511



The information contained herein is provided for general information purposes only and is not intended nor to be construed as a warranty, an offer, or any representation of contractual or other legal responsibility.

FocalPoint and *Titanium* are trademarks of The Babcock & Wilcox Company.



RENEWABLE | ENVIRONMENTAL | THERMAL

Established in 1867, Babcock & Wilcox is a global leader in renewable, environmental and thermal technologies and services for power and industrial applications.

For more information or to contact us, visit our website at www.babcock.com.